# Flat 3 113A Gosford Street Coventry CV1 5DL Property type Mid-floor flat Total floor area Energy rating D Valid until: 9 August 2031 Certificate number: 7139-5628-6000-0272-2206 Valid until: 9 August 2031 Certificate number: 7139-5628-6000-0272-2206 Zertificate number: 7139-5628-6000-0272-2206

### Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

# **Energy efficiency rating for this property**

This property's current energy rating is D. It has the potential to be C.

See how to improve this property's energy performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- · very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Window	Fully double glazed	Average
Main heating	Room heaters, electric	Very poor
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric instantaneous at point of use	Very poor
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(other premises below)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 330 kilowatt hours per square metre (kWh/m2).

Environmental impa property	act of this	This property's potential production	1.6 tonnes of CO2
One of the biggest contributors to climate change is carbon dioxide (CO2). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO2 emissions.		By making the <u>recommended changes</u> , you could reduce this property's CO2 emissions by 0.0 tonnes per year. This will help to protect the environment.	
An average household produces	6 tonnes of CO2	Environmental impact rating assumptions about average	
This property produces	1.6 tonnes of CO2	energy use. They may not reflect how energy is consumed by the people living at the property.	

### How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from D (67) to C (75).

Recommendation Typical installation cost Typical yearly saving

1. High heat retention storage heaters £400 - £600 £153

### Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

# Estimated energy use and potential savings

Estimated yearly energy cost for this property	£579
Potential saving	£153

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in <u>how to improve this property's energy performance</u>.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u> (<a href="https://www.simpleenergyadvice.org.uk/">https://www.simpleenergyadvice.org.uk/</a>).

### Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

Space heating	2013 kWh per year
Water heating	862 kWh per year

## Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive Renewable Heat Incentive payments (https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

### Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name Steven Messam Telephone 024 76 444 111

Email <u>commercial@midlandepc.co.uk</u>

### Accreditation scheme contact details

Accreditation scheme Elmhurst Energy Systems Ltd

Assessor ID EES/019667 Telephone 01455 883 250

Email enquiries@elmhurstenergy.co.uk

### **Assessment details**

Assessor's declaration No related party
Date of assessment 2 August 2021
Date of certificate 10 August 2021

Type of assessment RdSAP